



- Legend:**
- CLEANERS SOCKET
 - TWIN SOCKET REQUIRED BY EXHIBITION DESIGNER
 - SOCKET REQUIRED BY EXHIBITION DESIGNER
 - TWIN SWITCHED SOCKET OUTLET
 - TWIN DATA OUTLET
 - DISTRIBUTION BOARD
 - DATA CABINET
 - HEARING AID INDUCTION LOOP
 - INCOMING ELECTRICAL SERVICE
 - DATA OUTLET FOR WIFI ROUTER
 - DEDICATED WHEELCHAIR CHARGING OUTLET
 - PROJECTOR
 - PROJECTOR CONTROL EQUIPMENT
 - UNSWITCHED FUSED CONNECTION UNIT FOR:
AWCP - ACCESSIBLE WC CALL PANEL
IAP - INTRUDER ALARM PANEL
RIP - REFUGEE INTERCOM PANEL

- SWITCHED FUSED CONNECTION UNIT FOR:
AC - AIR CURTAIN
ACD - ACCESS CONTROLLED DOOR
ACL - ACCESS CONTROLLED LIFT
AVI - AUDIOVISUAL INTERCOM
B - BOILER
BMS - BUILDING MANAGEMENT SYSTEM
CCTV - CCTV
EWH - ELECTRIC WATER HEATER
HAIL - HEARING AID INDUCTION LOOP
HD - HAND DRYER
H/S - HEADSET CHARGING
HWC - HOT WATER CYLINDER
MD - MOTORISED DOORS
P - PUMP
RAD - ELECTRIC RADIATOR
SGW - SALTO GATEWAY
- SINGLE DATA OUTLET FOR:
ACD - ACCESS CONTROLLED DOOR
ACL - ACCESS CONTROLLED LIFT
AWCP - ACCESSIBLE WC CALL PANEL
AVI - AUDIOVISUAL INTERCOM
CCTV - CCTV
S - SALTO NODE
SGW - SALTO GATEWAY
T - TELEPHONE FOR LIFT BY REDCARE

- Notes:**
1. DO NOT SCALE THIS DRAWING. ALL DIMENSIONS IN MILLIMETRES UNLESS OTHERWISE STATED.
 2. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL RELEVANT ARCHITECT'S STRUCTURAL ENGINEERS AND M&E DRAWINGS AND THE M&E SPECIFICATION, SAMPLES SHEET AND ROOM DATA SHEETS.
 3. ALL ITEMS OF EQUIPMENT SHALL BE INSTALLED AS TO THE MANUFACTURER'S RECOMMENDATIONS.
 4. ALL INFORMATION AND LAYOUTS DETAILED ON THIS DRAWING ARE SUBJECT TO SITE DIMENSION CHECKS.
 5. ALL WIRING SHALL BE CONCEALED VIA CAST IN CONDUIT. THIS REQUIRES DETAILED COORDINATION WHICH SHALL BE UNDERTAKEN BY THE ELECTRICAL SUB-CONTRACTOR.
 6. THIS DRAWING SHOWS ALL OF THE SMALL POWER FOR CLIENT'S REQUIREMENTS. ALL SMALL POWER REQUIREMENTS FOR PLANT SHALL BE DESIGNED AND INSTALLED BY THE CONTRACTOR.

SAFETY, HEALTH AND ENVIRONMENTAL INFORMATION
FOR DETAILS OF SITE-WIDE AND GENERAL RISKS, TO BE READ IN CONJUNCTION WITH THESE NOTES, SEE THE CONTRACT DOCUMENTS AND, WHERE WORKS ARE NOTIFIABLE, THE PRE-CONSTRUCTION INFORMATION PACK ISSUED BY THE CDM CO-ORDINATOR
IN ADDITION TO THE RISKS NORMALLY ASSOCIATED WITH THE TYPES OF WORK DETAILED ON THIS DRAWING, NOTE THE FOLLOWING RISKS AND INFORMATION:
DISMANTLING / DEMOLITION (Future)
Dl. Dil. Diii. Div.
IT IS ASSUMED THAT ALL WORKS WILL BE CARRIED OUT BY A COMPETENT CONTRACTOR WORKING, WHERE APPROPRIATE, TO AN APPROVED METHOD STATEMENT

T02	03.04.19	OJR	TXK	NIS	APPLIANCES REMOVED AND RECOLLECTED
T01	07.03.19	ES	TXK	NIS	TENDER ISSUE
Rev	Date	By	Chk	Aprvd	Description

PROJECT
Tavistock Guildhall

CLIENT

Tavistock Guildhall



www.methodllp.com Swindon Tel: 01793 822044

DRAWING TITLE
Proposed Small Power & Data Layout
Ground Floor

SUITABILITY
D2 - FOR TENDER

DATE	SCALE	DRWN BY	CHK BY	APVD BY
26.01.17	1:50 - A1	BJP	NJS	NJS

DRAWING NUMBER	REVISION NO.
716LGH-MET-00-00-DR-E-Ss_70-0001	D2 - T02

Scaling Note: Do NOT scale from this drawing.