



ACCESS CONTROL LIFT
LINKED TO RECEPTION
KEY SWITCH FOR
MOTORISED DOORS
AUDIOVISUAL INTERCOM
LINKED TO RECEPTION

Legend:

	DUAL LED PIR/MOTION DETECTOR		ACCESSIBLE WC CALL PANEL
	FUTURE CCTV LOCATION CONSISTING OF 1No. SINGLE DATA OUTLET		INTRUDER ALARM ZONE FOR TOWN COUNCIL
	CCTV		INTRUDER ALARM ZONE FOR SHARED
	CCTV MOTORING POINT CONSISTING OF 1No. SFCU AND DATA CABINET WITH PATCH PANEL		INTRUDER ALARM ZONE FOR EXHIBITION
	FIRE ALARM PANEL		AWC RESET BUTTON
	INTRUDER ALARM PANEL		AWC PULL CORD
	ACCESSED CONTROLLED LIFT		AWC EMERGENCY FLASHING BEACON
	ACCESSED CONTROLLED DOOR		RED BREAK GLASS
	REFUGE INTERCOM PANEL		GREEN BREAK GLASS
	INTRUDER ALARM KEYPAD LINKED BACK TO MAIN INTRUDER ALARM PANEL IN GATEWAY RECEPTION		PUSH TO EXIT BUTTON
	AUDIOVISUAL INTERCOM		SMOKE DETECTOR WITH ALARM AND FLASHING BEACON
	AUDIOVISUAL INTERCOM AND DOOR RELEASE		SMOKE DETECTOR WITH ALARM
	PROXIMITY CARD READER		HEAT DETECTOR WITH ALARM AND FLASHING BEACON
	SALTO ACCESS CONTROLLED DOOR		REED SWITCH
			AWC RESET BUTTON

Notes:

- DO NOT SCALE THIS DRAWING. ALL DIMENSIONS IN MILLIMETRES UNLESS OTHERWISE STATED.
- THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL RELEVANT ARCHITECT'S STRUCTURAL ENGINEERS AND M&E DRAWINGS AND THE M&E SPECIFICATION, SAMPLES SHEET AND ROOM DATA SHEETS.
- ALL ITEMS OF EQUIPMENT SHALL BE INSTALLED AS TO THE MANUFACTURER'S RECOMMENDATIONS.
- ALL INFORMATION AND LAYOUTS DETAILED ON THIS DRAWING ARE SUBJECT TO SITE DIMENSION CHECKS.
- INTRUDER ALARM REED SWITCHES SHALL BE INSTALLED ON BOTH LEAVES OF ALL DOUBLE LEAF AND DOOR AND A HALF LEAF DOORS.
- ALL EQUIPMENT SHALL BE INSTALLED IN MAINTAINABLE LOCATIONS.
- ALL WIRING SHALL BE CONCEALED VIA CAST IN CONDUIT. THIS REQUIRES DETAILED COORDINATION WHICH SHALL BE UNDERTAKEN BY THE ELECTRICAL SUB-CONTRACTOR.

SAFETY, HEALTH AND ENVIRONMENTAL INFORMATION	
FOR DETAILS OF SITE-WIDE AND GENERAL RISKS, TO BE READ IN CONJUNCTION WITH THESE NOTES, SEE THE CONTRACT DOCUMENTS AND, WHERE WORKS ARE NOTIFIABLE, THE PRE-CONSTRUCTION INFORMATION PACK ISSUED BY THE CDM CO-ORDINATOR	
IN ADDITION TO THE RISKS NORMALLY ASSOCIATED WITH THE TYPES OF WORK DETAILED ON THIS DRAWING, NOTE THE FOLLOWING RISKS AND INFORMATION:	
DISMANTLING / DEMOLITION (Future)	
Dt.	
Dtl.	
Div.	
IT IS ASSUMED THAT ALL WORKS WILL BE CARRIED OUT BY A COMPETENT CONTRACTOR WORKING, WHERE APPROPRIATE, TO AN APPROVED METHOD STATEMENT	

THIS DRAWING IS NOT TO BE USED FOR CONSTRUCTION. THIS DRAWING SHOWS DESIGN INTENT ONLY. THE CONTRACTOR SHALL COMPLETE THE DESIGN BASED ON THE INFORMATION PROVIDED ON THIS DRAWING, THE M&E SPECIFICATION, THE ROOM DATA SHEETS AND THE OTHER DOCUMENTS COMPILING THE EMPLOYER'S REQUIREMENTS

T02	03.04.19	OJR	TXK	NIS	FIRE ALARM RELOCATED AND REMOVED
T01	07.03.19	ES	TXK	NIS	TENDER ISSUE
Rev	Date	By	Chk	Aprvd	Description

PROJECT
Tavistock Guildhall

CLIENT
Tavistock Guildhall



www.methodllp.com Swindon Tel: 01793 822044

DRAWING TITLE
Proposed Security, Access Control & Fire Alarm Services Ground Floor

SUITABILITY
D2 - FOR TENDER

DATE	SCALE	DRWN BY	CHK BY	APVD BY
04.01.2019	1:75 - A1	BMAP	TXK	NIS

DRAWING NUMBER	REVISION NO.
716LGH-MET-00-00-DR-E-Ss_75-0002	D2 - T02

Scaling Note: Do NOT scale from this drawing.