AUDIOVISUAL INTERCOM AND DOOR RELEASE
LINKED TO AVI AT BOTTOM 08 STAIRCASE IN G31
GATEWAY RECEPTION

Legend:

ACD	ACCESSED CONTROLLED DOOR
ACI+DR	AUDIOVISUAL INTERCOM WITH DOOR RELEASE
▬▬▬	INTRUDER ALARM ZONE FOR TOWN COUNCIL.
▬▬▬	INTRUDER ALARM ZONE FOR SHARED

Notes:

1. DO NOT SCALE THIS DRAWING. ALL DIMENSIONS IN MILLIMETRES UNLESS OTHERWISE STATED.

2. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL RELEVANT ARCHITECT'S STRUCTURAL ENGINEERS AND M&E DRAWINGS AND THE M&E SPECIFICATION, SAMPLES SHEET AND ROOM DATA SHEETS.

3. ALL ITEMS OF EQUIPMENT SHALL BE INSTALLED AS TO THE MANUFACTURER'S RECOMMENDATIONS.

4. ALL INFORMATION AND LAYOUTS DETAILED ON THIS DRAWING ARE SUBJECT TO SITE DIMENSION CHECKS.

5. INTRUDER ALARM REED SWITCHES SHALL BE INSTALLED ON BOTH LEAVES OF ALL DOUBLE LEAF AND DOOR AND A HALF LEAF DOORS.

6. ALL EQUIPMENT SHALL BE INSTALLED IN MAINTAINABLE LOCATIONS.

7. ALL WIRING SHALL BE CONCEALED VIA CAST IN CONDUIT. THIS REQUIRES DETAILED COORDINATION WHICH SHALL BE UNDERTAKEN BY THE ELECTRICAL SUB-CONTRACTOR.

Rev	Date	By	Chk	Aprvd	Description
T02	03.04.19	OH	TXK	NJS	FIRE ALARM ADDED
T01	07.03.19	EH	TXK	NJS	TENDER ISSUE

PROJECT
Tavistock Guildhall

CLIENT

Tavistock Guildhall

Method Consulting

www.methodllp.com   Swindon Tel: 01793 822044

DRAWING TITLE
Proposed Security, Access Control & Fire Services Second Floor

SUITABILITY
D2 - FOR TENDER

DATE	SCALE	DRWN BY	CHK BY	APVD BY
08.01.19	1:50 - A1	BMAP	TXK	NJS

DRAWING NUMBER	REVISION NO.
716LGH-MET-00-02-DR-E-Ss_75-0002	D2- T02

Scaling Note: Do NOT scale from this drawing.