


- NOTES
1. ALL DIMENSIONS ARE TO BE CHECKED ON SITE BEFORE THE COMMENCEMENT OF WORKS. ANY DISCREPANCIES ARE TO BE REPORTED TO THE ARCHITECT & FROM THE DRAWINGS.
  2. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL RELEVANT ENGINEERS' CONSULTANT DRAWINGS AND SPECIFICATIONS. THIS DRAWING IS THE PROPERTY OF THE ENGINEERING CONSULTANTS AND IS NOT TO BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, WITHOUT THE WRITTEN PERMISSION OF THE ENGINEERING CONSULTANTS.
  3. ALL WORK TO COMPLY WITH THE RELEVANT BRITISH STANDARDS, CODES OF PRACTICE AND BUILDING REGULATIONS.
  4. THIS DRAWING SHOWS THE RESULTS OF THE INTRUSIVE INVESTIGATION AND AREAS REQUIRING ADDITIONAL INVESTIGATION.
  5. RESULTS ARE REPRESENTATIVE OF THE INVESTIGATION POINTS ONLY. THE ACTUAL CONSTRUCTION MAY VARY.



OBSERVATIONS			
C01	SMALL LOOSE DEBRIS ONLY/GENERALLY SOLID	FB01	JOISTS THROUGH, NO APPARENT LOAD BEARING
C02	GOOD	FB02	JOISTS THROUGH, NO APPARENT LOAD BEARING
C03	GOOD	FB03	STUD - NON STRUCTURAL
C04	SOLID BRICK 310mm LONG, 40mm FINISHES / 25mm FINISHES	FB04	STUD - NON STRUCTURAL
C05	NOT THROUGH, SOME LOOSE BUT ON THE WHOLE STABLE	FB05	
C06	SOME LOOSE IN MIDDLE OF WALL	FB06	
C07	SOLID		
C08	LOOSE RUBBLE		
C09	MASONRY GYV JUT FLUE - MASONRY BRICKED NOT LOOSE		
C10	FRACTURED INTERNALLY, 1200mm LONG		

KEY:	
C01	CORE THROUGH WALL.
FB	FLOOR BREAKOUT.
BO	CEILING BREAKOUT.
S	SOLID FLOOR.
SUS	SUSPENDED FLOOR.

CLIENT  
**TAVISTOCK GUILDHALL**

PROJECT  
**TAVISTOCK GUILDHALL**

TITLE  
**INTRUSIVE INVESTIGATION RESULTS, LOWER GROUND FLOOR PLAN, SHEET 1**

HYDROCK PROJECT NO.  
**C-03482**

STATUS DESCRIPTION  
**SUITABLE FOR INFORMATION**

DRAWING NO. (PROJECT CODE, ORGANISATION CODE, DATE, TYPE, SCALE, NUMBER)  
**TGH-HVD-XX-LG-DR-S-0001**

STATUS  
**S2**

REVISION  
**P02**

REVISIONS

REV	DATE	BY	CHECKED BY	DATE	APPROVED BY	DATE
P02	08/02/19	ECM/ETS	08/02/19	JCM/ES	08/02/19	
P01	11/12/18	ECM/ETS	11/12/18	ECM/ETS	11/12/18	

Hydrock  
1-441(0) 7521347515  
e:info@hydrock.com